



- NOTES:**
- CONTRACTOR TO PROVIDE SMUD METERING ENCLOSURE AND REQUIRED CT MOUNTING BASES. UTILITY METER TO BE PROVIDED BY SMUD. CONTRACTOR SHALL COORDINATE WITH THE DISTRICT FOR SMUD METER INSTALLATION
  - CIRCUIT ORIGINATED FROM OPERATION BUILDING ELECTRICAL ROOM TO STAFF PARKING AREA VIA EXISTING CONDUIT P1001, P1001A AND HANDHOLE HH100394.



PRIMARY	SUB
---------	-----

REVISIONS					
ZONE	REV.	DESCRIPTION	BY	DATE	APP.
	1	ADDENDUM #1	WO	7/25	

LINE IS 2 INCHES AT FULL SIZE (IF NOT 2"-SCALE ACCORDINGLY)

FILE **E10**

DRAWN K. M. JOSE

DESIGNED W. OUYANG

CHECKED \_\_\_\_\_



SACRAMENTO REGIONAL WASTEWATER TREATMENT PLANT SRWTP ELECTRIC VEHICLE CHARGING STATIONS

**RFB 8343**  
CONTRACT NUMBER

ELECTRICAL

SINGLE LINE DIAGRAM  
MCC12A

SCALE  
NO SCALE

DRAWING NUMBER  
**E10**

SHEET NUMBER  
10 OF 14