



ADDENDUM NO. 1

FOR RFB#8369 Secondary Sedimentation Tanks (SST) Beam Support Brackets


**SACRAMENTO REGIONAL COUNTY SANITATION DISTRICT
SACRAMENTO, CALIFORNIA**

The following change has been amended in RFB#8369

Please amend the following:

1. Add to the Contract Documents the attached Specification Section 05_10_00 – Structural Metal Framing. This Section provides additional requirements for material, welding procedure qualifications, and welder’s qualifications.
2. Drawing 62S01:
 - a. Steel Note S1: On second sentence replace reference to SPECIFICATION “05501” to read “05_10_00”.
 - b. Steel Note S2: Delete first sentence and replace it with “TIG OR GMAW WELDING PROCEDURES OF STRUCTURAL STAINLESS STEEL SHALL CONFORM TO THE REQUIREMENTS OF AWS D1.6.”
 - c. Steel Note S2: Delete second sentence.
 - d. Steel Note S2: On last sentence replace reference to TEST RECORDS PER “05100” to read “05_10_00”.

Thank you,


Tamblynn Stewart
Senior Contract Service Officer

May 4, 2020

Addendum No.1

RFB#8369