



ADDENDUM NO. 2

**TO THE PROSPECTIVE BIDDERS UNDER
RFB NO. 8347 - PRIMARY DECK REHABILITATION PROJECT – PHASE 2
SACRAMENTO REGIONAL COUNTY SANITATION DISTRICT
SACRAMENTO COUNTY, CALIFORNIA**

Receipt of this addendum must be acknowledged in the space at the bottom of the Cost Response page.


All prospective bidders are advised of the changes to the bid:

ADDENDUM ITEM	SECTION AND PAGE OR DRAWING NO.	LOCATION AND DESCRIPTION OF CHANGE
2.01	Questions and Responses	See Attachment
2.02	Cost Response Page	See Attachment
2.03	RFP	Proposal Submittal date changed to August 12 th , 2019 at 3:00 pm.

Addendum No. 2 is hereby made part of the Regional San RFB No. 8347.

Dated: **August 7, 2019**

DATE 8-7-2019

BY 
Aaron Bihlman
Project Manager
Regional San

DATE _____

BY _____
Tambi Stewart
District Issuing Officer
Regional San

****END OF SECTION****

RFP #8347 – Primary Deck Rehabilitation Project Phase 2

Questions:

- A. There does not appear to be adequate time allowed to complete the work based on the Intent to Award date, the allowable shutdown dates, and the time required to coordinate said shutdowns.
- 1) Per page 5 – Key Action Dates, Intent to Award is 8/26/19
 - 2) Per page 6 – Safety Requirements, *“The contractor should coordinate work at least one month in advance due to the significant coordination required to implement a full plant shutdown”*. Assuming coordination can begin as soon as award is issued, the earliest a shutdown could be implemented is 9/26/19.
 - 3) Per Attachment No. 3 the only shutdown available between 9/26/19 and the required completion date of 10/16/19 is on 10/7/19. A minimum of two shutdowns will be required to complete this scope of work.

Please extend the completion date and include at least one additional available shutdown.

- B. Page 9 – Project Approach: **Please confirm the following is not applicable to this RFP** *“The proposal shall clearly identify how the proposed solution maintains the integrity/function of the expansion joint. The proposal shall clearly identify what materials would be used for the repair. Data sheets and specifications for materials proposed for repairs can be attached in a separate proposal section without a page restriction. The proposal shall clearly identify if the work in the two separate conduits can be performed in a single plant shut down or multiple plant shut downs will be required.”*
- C. Page 26 – Sealed Cost Proposal: This page states *“The envelope for the top ranked consultant will be opened for the purpose of negotiating scope and fees related to the proposed agreement. If a mutually agreeable contract is not reached, Sacramento Regional County Sanitation District will disqualify the selected consultant and initiate negotiations with the next higher ranked consultant. The envelopes for the firms not selected will be returned unopened after contract negotiations are complete.”* This appears to be inconsistent with Page 28 – Proposal Ranking Criteria, where the “Total Project Cost” is worth 50 of a total 100 possible points. **Please confirm the statement on page 26 does not apply to this RFP.**
- D. Page 27 – Cost Response Page: **What bid item should we include the cost for the SS jacket work?**
- E. **What materials are being supplied by the owner.**

District Response:

- A. The completion date is extended to November 16th, to allow for one additional shutdown if weather and conditions allow. The District cannot guarantee a date for that shutdown and may have to fit it into a good weather window.**
- B. Confirmed. Any references to an expansion joint in the RFP such as on Page 9 are not applicable to this RFP.**
- C. Confirmed. The statement on page 26 as indicated in the above question is not relevant to this RFP. The total project cost is considered as shown in the Proposal Ranking criteria.**
- D. See Cost Response Page attached. New line item #4 refers to the SS Jacket work.**
- E. The District is providing the Stainless steel slide gate rails, the column repair stainless steel jacket with nuts. The district will not be providing anchor bolts or holobolts.**

COST RESPONSE PAGE

Provide a complete cost response indicating unit price if applicable. Proposals must be submitted on the cost response form furnished within this RFP. Proposals not received on the specified form will be rejected. Proposals are to be clear and legible. Errors in mathematical calculations will be corrected with unit price governing. The corrected total shall be deemed the amount proposed.

The cost of all labor, material and equipment necessary for the completion of the work itemized, even though not shown or specified, shall be included in the unit price for the item shown herein.

The Sacramento Regional County Sanitation District reserves the right to increase or decrease the quantity of any item or omit items as may be deemed necessary, and the same shall in no way effect or make void the contract, except that appropriate additions or deductions from the contract total price will be made at the stipulated unit price.

The Sacramento Regional County Sanitation District reserves the right to reject any or all proposals, to waive any informality or irregularity in any proposal or the proposal procedure, and to delete any items of work in the award of contract.

Complete the “Line Item Total” columns in legible handwriting or with typed figures.

Item	Description	Estimated Quantity	Unit	Unit Price (\$/unit)	Line Item Total
1	Finalize Project Workplan, Mobilization & Demobilization (Not to exceed 10% of Total Proposal)	1	LS		
2	Guide Rail Installation.	1	LS		
3.	Concrete Deck Demolition and Hatch Installation including Stainless Steel Frame and Hatch.	1	LS		
4.	Construction of all work associated with the primary effluent channel column repair, complete as shown.	1	LS		
5.	Carbon Steel Test Gate: Fabrication and Testing.	2	EA		
Total Proposal Amount					\$
<div style="margin-bottom: 10px;">_____</div> <div style="margin-bottom: 10px;">Signature of Proposer</div> <div style="margin-bottom: 10px;">_____</div> <div style="margin-bottom: 10px;">Title</div>					

We have received _____ of _____ addendums.