

Questions and Answers #2
RFP#8350 Sodium Hydroxide

1) How large are the caustic tank systems at N52 and SRWTP?

N52: One tank with a 5000 gal capacity, overflow at 4700 gal

Area 9: Two tanks, each has a 6000 gal capacity, high level alarm at approximately 5900 gal

2) Can full loads be delivered-more like 4300-4400 gallons instead of 4200 gallons/delivery?

As a safeguard from reportable spills, deliveries amounts at N52 are limited to 4300 gal.

Area 9 delivery volumes will vary as the site's needs vary year by year, but volumes can be full loads. Historically deliveries have been full loads of ~4770 gallons.