



ADDENDUM NO. 2

**RFP#8381 Regional San Interceptors
Low Voltage VFD Replacement Project**

SACRAMENTO REGIONAL COUNTY SANITATION DISTRICT

The following changes are amended in RFP#8381 Regional San Interceptors
Low Voltage VFD Retrofit Project:

The following VFDs are to be retrofitted

Iron Point Pump Station (N40)

Robicon 454GT 200HP AFD 111

Robicon 454GT 200HP AFD 121

Power Inn Pump Station (N52)

Robicon 454GT 200HP AFD 100

Robicon 454GT 200HP AFD 200

Robicon 454GT 200HP AFD 400

Note: N52 AFD 300 has been removed from the lineup and replaced with
AFD 400.

The following is supplemental information related to N52:




Figure 1 - Motor Name Plate Data for AFD 100, 200, 400

Best regards,

Tamblynn Stewart
Tamblynn Stewart
Sr. Contract Services Officer

February 16, 2021

Addendum No. 2

RFP#8381