



Questions and Answers
TO THE PROSPECTIVE PROPOSERS UNDER RFP NO. 8352
Regional San Interceptors N40 and N53 Low Voltage VFD
Replacement Project
SACRAMENTO REGIONAL COUNTY SANITATION DISTRICT
OPERATION AND MAINTENANCE DEPARTMENT - ELECTRICAL SHOP

- Will the Sacramento Regional County Sanitation District allow deviations to the specified Terms and Conditions – specifically, the addition of an overall financial limit of liability and liability exclusions for indirect or consequential damages? **Please list this as an exception on the Exceptions Response Page (page #28 of the RFP).**
- Will the District waive the specified Wage Determination requirements if all on-site services are provided by Siemens Exempt Professional employees (and not Non-Exempt craft labor). **Please list this as an exception on the Exceptions Response Page (page #28 of the RFP).**
- Will the District accept drive retrofit as an approved alternate to the specified drive replacement? **No.**
- If retrofit is approved, will the District require UL labeling of the completed retrofit equipment? **The District will not accept retrofits.**
- If retrofit is approved, will the District require prototype equipment shake table testing to simulate a seismic event or is a calculation sufficient? **The District will not accept retrofits.**
- Is Siemens an Acceptable Product for existing drive replacement? **Yes.**
- Will the District approve 40-degree Celsius design instead of the 50-degree C rating as specified? **Yes.**
- Siemens understands no programmable logic controller code development or changes will be required for specified work. **Please confirm. There is no need for any programming to be completed. However, we will want to coordinate to verify that the VFD will properly exchange signals with the PLC.**
- What is the expectation of the Pre-Submission documentation due on October 18?
The product cutsheet information and marked up VFD specifications with each paragraph check marked to show compliance or marked to show deviations

When can vendors expect the answers back to questions submitted? **On October 18, 2019**

Thank you,

Ronald Baptista - PE

Associate Electrical Engineer - Sacramento Regional County Sanitation District