

Table C-2 - Summary of Corrosion Evaluation Testing Results

Boring ID	Sample ID	Middle Depth (ft)	USCS*	Soil pH	Minimum Resistivity ohm-cm (x1000)	Chloride ppm	Sulfate ppm
SWB-1	S-3	10.75	CH	6.98	1.07	3.6	58.7
SWB-3	S-3	10.70	ML	7.23	1.69	2.2	8.2
SWB-4	S-5	20.75	CL	6.72	1.66	3.7	18.1
SWB-6	S-6	23.25	CL	6.93	3.22	3.9	6.2
SWB-7	S-3	10.75	CH	6.86	4.02	5.1	4.0
SWB-9	S-2	10.75	CL	7.22	0.83	107.1	6.0
SWB-10	S-4	20.75	ML	7.07	1.80	0.9	14.0
SWB-11	S-2	10.75	ML	6.67	0.94	32.9	26.0
SWB-12	S-5	20.75	CH	7.39	0.94	3.4	11.9
SWB-13	S-7	25.75	CL	7.68	1.37	6.3	21.0
SWB-14	S-6	18.25	ML	7.03	1.29	2.1	6.9
SWB-15	S-3	10.75	CL	7.76	1.99	8.1	45.1
SWB-17	S-4	10.75	CL	7.74	1.3	2.2	21.2

*Unified Soil Classification System (USCS) symbols taken from corresponding soil layers reported on Boring Logs, see Appendix A.

DRAFT

